

TABLE OF THE SHELVED FLAGS CHECKED BY gherardini ON 2019-08-14_14:01:55

Shelved by	Date shelving	Flag	Condition flag	UTC start	UTC stop	Comment	Checked	Additional note
berni	09/03/19 22:49	DET_Lab_Dust	mean_ENV_DETR_DUST_0P3UM_30	09/03/19 08:00	06/04/20 08:00	device unplugged because it can be a source of noise.	yes	none
berni	09/03/19 22:49	DET_Lab_Dust	mean_ENV_DETR_DUST_0P5UM_30	09/03/19 08:00	06/04/20 08:00	device unplugged because it can be a source of noise.	yes	none
berni	09/03/19 22:49	DET_Lab_Dust	mean_ENV_DETR_DUST_0P7UM_30	09/03/19 08:00	06/04/20 08:00	device unplugged because it can be a source of noise.	yes	none
berni	09/03/19 22:49	DET_Lab_Dust	mean_ENV_DETR_DUST_1UM_30	09/03/19 08:00	06/04/20 08:00	device unplugged because it can be a source of noise.	yes	none
berni	11/06/19 10:31	NE_TE	mean_ENV__NE_F2_TE1_60	11/06/19 08:00	03/09/19 08:00	sensor broken	yes	none
fabiog	03/06/19 09:32	ACS_DET_ALARMED	mean_HVAC__DET_FLUX_IN_10	03/06/19 00:00	03/09/19 09:00	sensor broken; waiting for new maintenance contract with K&P	yes	none
fabiog	03/06/19 09:32	ACS_DET_ALARMED	mean_HVAC__DET_FLUX_OUT_10	03/06/19 00:00	03/09/19 09:00	sensor broken; waiting for new maintenance contract with K&P	yes	none
fabiog	23/07/19 10:19	foxbox	ping_foxbox1	23/07/19 00:00	03/09/19 09:00	comment: "Foxbox" is temporarily out of order. It will be fixed as soon as possible.	yes	none
fabiog	13/08/19 08:34	ACS_NE_ALARMED	mean_HVAC__NEB_COLD_TE_60	13/08/19 00:00	20/08/19 09:00	Anche se la temperatura dell'acqua refrigerata e' piu bassa, l'anomalia viene comensata dalla valvola del loop caldo	yes	none
fabiog	13/08/19 08:34	ACS_NE_ALARMED	mean_HVAC__NEB_COLD_TE_ERR_60	13/08/19 00:00	20/08/19 09:00	Legata alla Hvac neb cold te	yes	none
fabiog	14/08/19 06:46	DeadChannel_CEB	delta_ENV_CEB_DUST_0P3UM_3600	14/08/19 06:00	20/08/19 06:00	Particle counter out of order.	yes	none
menzione	17/07/19 08:20	ACS_INJ_SAS	mean_HVAC__INJ_SAS_PRES_10	17/07/19 06:00	03/09/19 06:00	Waiting for installation of the new sensor	yes	none
menzione	30/07/19 16:08	CB_Hall	mean_ENV__CEB_N_TE_10	30/07/19 09:00	30/08/19 09:00	Temperature probe is broken (DeRosa will replace it)	yes	none
menzione	06/08/19 09:10	NE_Electr	SAT__NE_PDU_SOCKET3	06/08/19 07:00	01/10/19 07:00	Socket used by A.Gennai for the power supply of the I/O board for Naples tiltmeter	yes	none
menzione	06/08/19 10:30	WI_CO2_Laser	mean_TCS_WI_CO2_PWRLAS_10	06/08/19 07:00	03/09/19 07:00	Possible problem with the monitoring channel, to monitor in the next days. (Nardecchia)	yes	none
pasqualetti	25/07/19 15:02	O2_WE	mean_VAC__WE_O2_TUNNELDOOR_UP_5	25/07/19 10:15	24/09/19 10:15	offline because malfunctioning	yes	none
pasqualetti	12/08/19 09:22	O2_NE	mean_VAC__NE_O2_TUNNELDOOR_UP_5	12/08/19 09:00	27/08/19 09:00	sensor to be checked	yes	none
pasqualetti	13/08/19 12:44	Pressure	VAC_TUBE1200N_RGAGa5__018	13/08/19 09:00	20/08/19 09:00	out for maint inetrvention	yes	none
soldani	10/06/19 12:10	ACS_COB	mean_INF__COB_FARM_FREE_TE_60	10/06/19 09:00	30/09/19 09:00	Canale superfluo in estate; l'impianto di free cooling e' attivo solo nella stagione invernale	yes	none
soldani	20/06/19 08:32	ACS_INJ_ALARMED	mean_HVAC__INJ_FLUX_OUT_10	20/06/19 08:00	10/09/19 09:00	waiting for new maintenance contract for probe substitution	yes	none
soldani	09/08/19 10:16	ACS_WE_ALARMED	mean_INF__WEB_HEATER_TE_IN_60	09/08/19 09:00	02/09/19 09:00	position of this probe has to be changed.	yes	none
soldani	10/08/19 22:49	ACS_NE_ALARMED	mean_INF__NEB_CHILLER_TE_IN_60	10/08/19 20:00	20/08/19 08:00	See my mail offre yesterday for motivation	yes	none